

**Kentucky Transportation Cabinet  
Department of Highways  
Frankfort, Kentucky 40622**

Meeting Minutes  
December 5, 2016

**Background**

A Pre-bid conference was held for FE02 051 0041 B0002R, CID #162983 in Frankfort, Kentucky (Dist. 5).

**Present:**

***KYTC***

Evan Dick	KYTC	David Steele	KYTC
-----------	------	--------------	------

***Contractors***

Ronald Boyd	ABHB & Svoboda	Rob Agee	E & B Paving, Inc.
Judy Harp	Judy C. Harp Co.	Hunter Judy	Hall Contracting
John Crace II	Intech Contracting	Tyler Schoborg	Evers Steel

***Others***

Rick Younce	KTC	Mike Lawler	Stantec
Alan Farmer	Stantec	Craig Klusman	AECOM

**A. Pre-Bid Conference**

The meeting was convened at 1:30 P.M (Eastern Time) by Evan Dick of KYTC.

**Question and Answer**

Q: Judy Harp from Judy C. Harp Co. asked if the 46' long angle that is to be installed had to be continuous.

A: Craig Klusman stated yes, but if the contractor wanted to submit a proposal to splice two pieces for this angle they would have to get it approved by the engineer.

Q: Judy Harp from Judy C. Harp Co. stated that their supplier has told them it would be difficult to get the angle as one piece and asked if they would entertain having a splice.

A: Evan Dick stated yes, but it would have to be approved.

Q: Judy Harp from Judy C. Harp Co. asked if there is to be a joint replacement over the rockers.

A: Mike Lawler stated no.

Q: Judy Harp from Judy C. Harp Co. asked if removing and replacing the expansion joint is to be done later.

A: Mike Lawler stated that the replacement is in another contract and should not be in this project.

Q: Tyler Schoborg from Evers Steel stated that he thought there was a set of plans from AECOM regarding adding angles to the girder bridge.

A: Evan Dick stated that it is on page 19 of the proposal and Mike Lawler stated there are a set of plans also.

Q: Tyler Schoborg from Evers Steel asked if there was anything else not applicable other than the removing and replacement of the expansion joint.

A: Mike Lawler stated no.

Q: John Crace II from Intech Contracting stated that they also reference the joint replacement in the notes on the last page of the plans.

A: Mike Lawler stated to delete it.

Q: Tyler Schoborg from Evers Steel stated that he did not see a note regarding the finish coat and asked if that was a 2 or 3 coat system or if it is just being primed.

A: Mike Lawler stated there is a paint note on page 2 of the plans. Evan Dick stated that there is a note on page 18 of the proposal and section 3.27 also addresses the coatings.

Q: Tyler Schoborg from Evers Steel asked if he understood correctly there will be no finish coat and just prime coat.

A: Evan Dick stated yes.

Q: Tyler Schoborg from Evers Steel asked if the federal paint number would be provided.

A: Evan Dick stated yes.

Q: Ronald Boyd from ABHB & Svoboda asked if he could get a copy of the sign in sheet.

A: Evan Dick stated yes.

Meeting was adjourned at approximately 1:55 P.M.

Minutes submitted by: Rick Younce

Approved by: Evan Dick