

**Kentucky Transportation Cabinet  
Department of Highways  
Frankfort, Kentucky 40622**

Meeting Minutes  
September 7, 2011

**Background**

A Pre-bid conference was held for project no. BRZ 1103 (249) in London, Kentucky (Dist. 11).

**Present:**  
***KYTC***

Tom Mathews	KYTC	Dean Croft	KYTC
Michael Baase	KYTC	Audra Smallwood	KYTC
Michael West	KYTC		

***Contractors***

Phil Zembillas	Troy Painting Inc.	Anthony Zembillas	Troy Painting Inc.
Brad Wilder	Jave, LLC	Emanuel Hazimihalis	Spartan Contracting Inc.
Emanuel Gialousis	Adelphi Inc. DBA G-Force Contracting	Tony Gialousis	Adelphi Inc. DBA G-Force Contracting
Emmanuil Klimis	Euro Painting, LLC	Steve Harp	Judy C. Harp Co.

***Others***

Rick Younce	KTC	Wade Wright	Sherwin Williams
-------------	-----	-------------	------------------

**A. Pre-Bid Conference**

The meeting was convened at 10:00 A.M (Eastern Time) by Tom Mathews of KYTC.

**Question and Answer**

Q: Emanuel Gialousis from G-Force Contracting asked if the state would entertain the contractor using black beauty as their blast media due to the location and the limited access to the bridge.

A: Mike Baase stated that KYTC will always entertain anything that is submitted but the contact as presented at this time is to do it as a recycle job. Tom Mathews from KYTC stated that they would review the weight limits on the structures leading to this bridge and if anything changes there will be an addendum issued.

**The blast media shall be recyclable steel grit.**

Q: Dean Croft from KYTC asked if there are any changes to the repairs on this bridge do they have to get the historical society to approve them.

A: Tom Mathews stated yes.

Q: Mike Baase from KYTC stated that this bridge currently has a posting of a 3 ton weight limit and asked if when the contractor started to remove gussets and vertical members, does the bridge need to be shut down.

A: There was a discussion concerning this question and Tom Mathews stated that he would check into it and if anything changes there would be an addendum posted.

[See addendum 1 for this contract CID No.112958](#)

Meeting was adjourned at approximately 10:30 A.M.

Minutes submitted by: Rick Younce

Approved by: Tom Mathews

**LAUREL COUNTY DISTRICT NO. 11**  
**BRZ 1103 (249)**  
**CID #112958    CALL 103**  
**06-30-2011 Pre-Bid Field Review Questions**

Q. Will existing structure plans be made available to the contractor?

**A. Yes, the existing structure plans will be posted under the “project related information” link on the Cabinet’s web site.**

Q. Can the structures on KY 490 that will have to be crossed handle the load of equipment that may be used by the contractor?

**A. Any equipment exceeding 32 tons shall be mobilized and staged from the north-west end of the structure on KY 490.**

Q. Can the Contactor use silicon in place of neoprene for the joint sealing at the south-east end of the structure?

**A. Yes, the Contactor shall be permitted to use silicon in accordance with the standard Specification.**

Q. Will night time work be permitted?

**A. Night time will be permitted as long as no complaints from residents in the surrounding area are received.**

Q. Will the Contractor be permitted to stage equipment on KY 89 at the north-west end of the bridge?

**A. Yes, Contactor shall be permitted to stage from KY 89. The Contractor shall arrange the lane closure signage as applicable.**

**Please check back with our web site for any new addendums, bulletins and information related to this proposal.**



## PRE-BID FIELD REVIEW SIGN-IN SHEET

[illegible]