



TRANSPORTATION CABINET

Frankfort, Kentucky 40622
www.transportation.ky.gov/

Steven L. Beshear
Governor

Michael W. Hancock, P.E.
Secretary

June 22, 2015

CALL NO. 405
CONTRACT ID NO. 152958
ADDENDUM # 1

Subject: Butler County, 016GR15M037-FE02
Letting June 26, 2015

(1) Added - Memorandum - Pages 1-6 of 6

Proposal revisions are available at <http://transportation.ky.gov/Construction-Procurement/>.

If you have any questions, please contact us at 502-564-3500.

Sincerely,

A handwritten signature in cursive script that reads "Robert C. Lewis".

Robert C. Lewis, P.E.
Acting Director
Division of Construction Procurement

RL:ks
Enclosures



An Equal Opportunity Employer M/F/D



TRANSPORTATION CABINET

Frankfort, Kentucky 40622
www.transportation.ky.gov/

Steven L. Beshear
Governor

Michael W. Hancock, P.E.
Secretary

MEMORANDUM

TO: Tom Mathews
Division of Maintenance
FROM: Brittany Stratton, Geologist II
UST/Hazmat Section
DATE: 06/08/2015
SUBJECT: Asbestos Inspection Report for
US 231 over Indian Camp Creek

This report is prepared to accompany the 10-day NOI for Demolition to the Division of Air Quality.
Please include all pages with submittal

Project and Structure Information

County: Butler

Bridge # 016B00001N

Description: Bridge inspected for asbestos containing materials (ACM's)

Results

Black Abutment Sealant: Tested negative for asbestos

Gray Abutment Sealant: Tested negative for asbestos

Conclusions

All samples tested negative for asbestos containing materials (ACM). No abatement is required.





Fax: (502) 491-7111

Analysis N #	256084	Address:	Butler County
Client Name:	KYTC		Bridge # 016 B00001N
Sampled By:	Brittany Stratton		US 231 Over Indian Camp Creek

[illegible]

Reviewed By:

Wintour Mendez
Signature

AJHA #1 02459

KENTUCKY
TRANSPORTATION
CABINET

Kentucky Transportation Cabinet
200 Metro Street, 5th Floor West
Frankfort, Kentucky 40622
(502) 564-7250 fax (502) 564-5655

Page 1



TRANSPORTATION CABINET

Frankfort, Kentucky 40622
www.transportation.ky.gov/

Steven L. Beshear
Governor

Michael W. Hancock, P.E.
Secretary

MEMORANDUM

TO: Tom Mathews
Division of Maintenance
FROM: Brittany Stratton, Geologist II
UST/Hazmat Section
DATE: 06/08/2015
SUBJECT: Asbestos Inspection Report for
US 231 over Barren River

This report is prepared to accompany the 10-day NOI for Demolition to the Division of Air Quality.
Please include all pages with submittal

Project and Structure Information

County: Butler

Bridge # 016B00002N

Description: Bridge inspected for asbestos containing materials (ACM's)

Results

Black Abutment Sealant: Tested negative for asbestos

Gray Abutment Sealant: Tested negative for asbestos

Conclusions

All samples tested negative for asbestos containing materials (ACM). No abatement is required.



MRS, Inc. Analytical Laboratory Division

Fax: (502) 491-7111

Analysis N #	256085	Address:	Butler County
Client Name:	KYTC		Bridge # 00002N
Sampled By:	Brittany Stratton		US 231 Over Barren River

[illegible]

Date Analyzed : 8-Jun-15
Analyst : Winterford Mensah

Reviewed By: Winterson Mervin
Signature

AJHA #1 02459

**KENTUCKY
TRANSPORTATION
CABINET**

Kentucky Transportation Cabinet
200 Metro Street, 5th Floor West
Frankfort, Kentucky 40622
(502) 564-7250 fax (502) 564-5655

Page 1