



TRANSPORTATION CABINET

Frankfort, Kentucky 40622
www.transportation.ky.gov/

Steven L. Beshear
Governor

Michael W. Hancock, P.E.
Secretary

April 14, 2011

CALL NO. 104
CONTRACT ID NO. 111013
ADDENDUM # 1

Subject: Scott County, STPR 4601 (030)
Letting April 29, 2011

(1)Added - Special Note - Page 19(a) of 246

Proposal revisions are available at <http://transportation.ky.gov/contract/>.

If you have any questions, please contact us at 502-564-3500.

Sincerely,

A handwritten signature in blue ink that reads "Ryan Griffith".

Ryan Griffith
Director
Division of Construction Procurement

RG:ks
Enclosures



An Equal Opportunity Employer M/F/D

Special Note for Dry Laid Rock Fence/Retaining Wall Reconstruction

1. The existing rock shall be used to relocate and re-build the rock fence however, if there is no suitable rock available for various wall components (i.e.; wallhead, tie rocks, etc.) then the engineer may deem it necessary to acquire additional rock from an acceptable source.
2. The Current Standard Specifications for Road and Bridge Construction Special Note For Dry-Laid Rock Fences (9T) will apply with the following additions and exceptions:
 - a) Section 3.5) Tie Rocks should not overhang or project on the side of the fence that faces the road. The rock should be flush with the face of the fence.
 - b) Cover Course should not overhang or project on the side of the fence that faces the road. Cover Course should be flush with the face of the fence.
 - c) The existing rock shall be used to relocate and re-build the rock fence however, if there is no suitable rock available for various wall components (i.e.; wallhead, tie rocks, etc.) then the engineer may deem it necessary to acquire additional rock from an acceptable source.
 - d) Batter: If the existing wall does not have any apparent batter, or does not match Figure 1 in Special Note 9T, then transition the fence to match the dimensions shown in Figure 1.

Quality Assurance

1. Workmanship: The Workmanship shall be of high quality, as recognized by the KYTC, Dry Stone Conservancy, Inc. (DSC), and dry stone industry standards. Poor or inferior workmanship (as determined by the engineer) is to be removed, replaced and corrected to conform to the standards of the dry-laid stone masonry trade.
2. Mason Qualification: All Dry Stone Masonry work will be accomplished under the direct supervision of a Mason qualified under the certification below:
 - a) DSC Basic Drystone Mason Qualifications: DSC level 1 ranking. DSC Basic Drystone Mason shall have at least two years experience, run their own business and train apprentices.