

GUARDRAIL GALV. THICKNESS WORKSHEET
TABLE 2, TYPE 2

SPOT 1

1. _____
 2. _____
 3. _____
 4. _____
 5. _____

Front

TOTAL _____ +5=
 AVG. _____

SPOT 2

1. _____
 2. _____
 3. _____
 4. _____
 5. _____

TOTAL _____ +5=
 AVG. _____

SPOT 3

1. _____
 2. _____
 3. _____
 4. _____
 5. _____

TOTAL _____ +5=
 AVG. _____

SPOT 1

1. _____
 2. _____
 3. _____
 4. _____
 5. _____

Back

TOTAL _____ +5=
 AVG. _____

SPOT 2

1. _____
 2. _____
 3. _____
 4. _____
 5. _____

Back

TOTAL _____ +5=
 AVG. _____

SPOT 3

1. _____
 2. _____
 3. _____
 4. _____
 5. _____

Back

TOTAL _____ +5=
 AVG. _____

FRONT _____
 BACK _____
 TOTAL _____ +1.7=
 *AVG. _____

FRONT _____
 BACK _____
 TOTAL _____ +1.7=
 **AVG. _____

FRONT _____
 BACK _____
 TOTAL _____ +1.7=
 ***AVG. _____


* Min. for single spot 3.6 oz/ft²

* _____
 ** _____
 *** _____

Sum of oz/ft² of spot 1, 2 & 3

TOTAL _____ +3 =
 AVG. _____

Minimum check limit triple spot test average 4.00 oz/ft²



Gage Type _____ Serial/State# _____ Date _____